

May 10, 2023

Inver Grove Heights City Council
 c/o Ms. Rebecca Kiernan, City Clerk
 Inver Grove Heights City Hall
 8150 Barbara Avenue
 Inver Grove Heights, Minnesota 55077

Dear Council Members:

SUBJECT: Maximum Contaminant Level Violation Monitoring, Inver Grove Heights, Dakota County, PWSID 1190014

Enclosed are the most recent results from water samples collected from your public drinking water supply. Past results indicated a maximum contaminant level (MCL) exceedance, as noted in the Notice of Violation letter previously sent by this office. Monitoring for the contaminant(s) will continue to occur on a quarterly basis. Below is a summary of the results:

Sampling Site: Treatment Plant #1

Contaminant: **Combined Radium (-226 & -228)**

MCL: 5.4 pCi/L

<u>Date Collected</u>	<u>Results</u>	<u>Units</u>	<u>Sample#</u>	<u>Annual Average</u>
03/22/2023	4.40	pCi/L	23C1071-01	5.1
10/10/2022	5.70	pCi/L	22J0320-01	6.0

Contaminant: **Gross Alpha in Water**

MCL: 15.4 pCi/L

<u>Date Collected</u>	<u>Results</u>	<u>Units</u>	<u>Sample#</u>	<u>Annual Average</u>
03/22/2023	6.70	pCi/L	23C1071-01	9.9
10/10/2022	14.00	pCi/L	22J0320-01	11.6

Enclosed is a sample public notice. Within 30 days, this notice or one containing similar information must be provided to the persons served by your water supply each quarter that the MCL is exceeded. A copy of the public notice and a signed statement verifying delivery of the notice from the person responsible for your water supply must be submitted to this office, c/o Andrew Karp.

Inver Grove Heights City Council


Page 2

May 2, 2023

PWSID 1190014

This report should be placed in your records and a copy maintained on or near the water supply premises and available for public inspection for not less than ten (10) years. If you have any questions, please contact Andrew Karp at 651-201-4668, or email andrew.karp@state.mn.us.

Sincerely,

A handwritten signature in black ink, appearing to read 'K R P', followed by a horizontal line.

Karla R. Peterson, P.E., Supervisor
Community Public Water Supply Unit
Environmental Health Division
P.O. Box 64975
St. Paul, Minnesota 55164-0975

KRP:AK

Enclosure

cc: Water Superintendent

Corey Larson, MDH St. Paul District Office

Jessie Kolar, MDH St. Paul District Office