

September 19, 2023

Inver Grove Heights City Council  
c/o Ms. Rebecca Kiernan, City Clerk  
Inver Grove Heights City Hall  
8150 Barbara Avenue  
Inver Grove Heights, Minnesota 55077

Dear Council Members:

**SUBJECT:** Maximum Contaminant Level Violation Monitoring, Inver Grove Heights, Dakota County, PWSID 1190014

Enclosed are the most recent results from water samples collected from your public drinking water system. Past results indicated a maximum contaminant level (MCL) exceedance, as noted in the Notice of Violation letter previously sent by this office. Monitoring for the contaminant(s) will continue to occur on a quarterly basis. Below is a summary of the results:

**Sampling Site: Treatment Plant #1**

Contaminant: **Combined Radium (-226 & -228)**

MCL: >5.4 pCi/L

<u>Date Collected</u>	<u>Results</u>	<u>Units</u>	<u>Sample#</u>	<u>Annual Average</u>
06/20/2023	6.20	pCi/L	23F1594-01	5.4
03/22/2023	4.40	pCi/L	23C1071-01	5.1
10/10/2022	5.70	pCi/L	22J0320-01	6.0

Contaminant: **Gross Alpha in Water**

MCL: >15.4 pCi/L

<u>Date Collected</u>	<u>Results</u>	<u>Units</u>	<u>Sample#</u>	<u>Annual Average</u>
06/20/2023	7.90	pCi/L	23F1594-01	9.3
03/22/2023	6.70	pCi/L	23C1071-01	9.9
10/10/2022	14.00	pCi/L	22J0320-01	11.6

Enclosed is a sample public notice. Within 30 days, this notice or one containing similar information must be provided to the persons served by your water system each quarter that the MCL is exceeded. A copy of the public notice and a signed statement verifying delivery of the notice from the person responsible for your water supply must be submitted to this office, c/o Allison Dodge.

Inver Grove Heights City Council

Page 2

September 19, 2023

PWSID 1190014

This report should be placed in your records and a copy maintained on or near the water system premises and available for public inspection for not less than ten (10) years. If you have any questions, please contact Allison Dodge at (651) 201-5278 or email [allison.dodge@state.mn.us](mailto:allison.dodge@state.mn.us).

Sincerely,



FOR:

Karla R. Peterson, P.E., Supervisor  
Community Public Water Supply Unit  
Environmental Health Division  
P.O. Box 64975  
St. Paul, Minnesota 55164-0975

KRP:AD

Enclosure

cc: Water Superintendent

Corey Larson, MDH St. Paul District Office

Andrew Karp, MDH St. Paul District Office